

The manufacturer may use the mark:



Valid until October 1, 2018 Revision 1.1 September 30, 2015



ANSI Accredited Program PRODUCT CERTIFICATION #1004

Certificate / Certificat Zertifikat / **合格証**

EPRO 1507123 C001

exida hereby confirms that the:

CSI 6500 SIS Digital Protection System

Emerson Epro, GmbH Gronau - Germany

Has been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 1 (SIL 1 Capable)

Random Capability: Type B Element

SIL 1 @ HFT=0; Route 2_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Safety Function:

The CSI 6500 is a logic solver that may be configured to implement various safety functions as described in the safety manual. It has special purpose input modules and relays outputs that allow protection against vibration, shaft displacement/position, speed and wrong direction hazards.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



Evaluating Assessor

Certifying Assessor

Page 1 of 2

Certificate / Certificat / Zertifikat / 合格証

EPRO 1507123 C001

Systematic Capability: SC 1 (SIL 1 Capable)

Random Capability: Type B Element

SIL 1 @ HFT=0; Route 2_H

PFD_{AVG} and Architecture Constraints must be verified for each application

Systematic Capability:

The Product has met manufacturer design process requirements of Safety Integrity Level (SIL) 1. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This Device meets *exida* criteria for Route $2_{\rm H}$.

| Device | λ_{SD} | λ _{su} | λ_{DD} | λ_{DU} |
|---------------------------------------|----------------|-----------------|----------------|----------------|
| per A6110 Module per SIF | 350 | 119 | 259 | 123 |
| per Active A6110 Input Sensor per SIF | 21 | 114 | 57 | 120 |
| per A6120 Module per SIF | 350 | 119 | 259 | 123 |
| per Active A6120 Input Sensor per SIF | 26 | 139 | 47 | 129 |
| per A6125 Module per SIF | 350 | 119 | 259 | 123 |
| per Active A6125 Input Sensor per SIF | 26 | 162 | 47 | 165 |
| per A6210 Module per SIF | 350 | 119 | 259 | 123 |
| per Active A6210 Input Sensor per SIF | 21 | 86 | 34 | 41 |
| per A6312 Module per SIF | 179 | 162 | 72 | 272 |
| per Active A6312 Input Sensor per SIF | 22 | 91 | 4 | 58 |
| per A6740 Module per SIF | 169 | 60 | 58 | 60 |
| per Active A6740 Output Relay per SIF | 0 | 39 | 0 | 33 |

IEC 61508 Failure Rates in FIT*

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{AVG} or PFH considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

EPRO 15-07-123 R002 V1R0

The following documents are a mandatory part of certification:

Assessment Report:

Safety Manual: MHM-97872

CSI 6500 SIS Digital Protection System



64 N Main St Sellersville, PA 18960