Emerson Device Revision History Information

(Following NAMUR Recommendation NE53)

Device Overview

Manufacturer: ____Emerson

Type of Device: Field Device/ Transmitter

Device: _Micro Motion™ 4200 Coriolis Configurable Inputs and Outputs Transmitter

Type: __Coriolis Transmitter

Revision History Summary

Release Date	SW Revision	HW Revision	Compatibility	Additional Details
March 2024	0102	01	DD	Page 2

EMERSON.

Emerson Device Revision History Information

(Following NAMUR Recommendation NE53)

Software Revision	0102
Hardware Revision	01
Option Code	NA
Impact on Functional Safety	Yes
Impact and change on safety parameters	Yes
Compatibility	DD Rev 0401
Manual	N/A
Reporting of a detected security vulnerability	No

Change Summary

Below is the list of changes made in Rev0102:

- 1) Methods have been updated to better handle out-of-range or invalid values during method execution.
- 2) Implemented alert notifications prior to performing Zero Verification, Zero Calibration, and all Density Calibration methods.
- Configure Totalizers/inventories has been added to guided setup page.
- 4) For Totalizer 1-7 and Inventory 1-7 digital values the label is changed to Total X Value and Inventory X Value (X=1 to 7).
- 5) For each Totalizer/Inventory group under Totalizer Control->Totalizers (1-7) and Inventories (1-7) added Source parameter.
- 6) Fixed multiple PWTTS issues.
- 7) Alert conditions which can be suppressed from alert Setup are updated with new alert validity (Alert Ignore conditions are added in Alert Condition Validity).
- 8) Alert conditions from alert setup are changed as per feature enabled in the device.
- 9) Description for SMV Abort Code 7 has been added in DD & UIRD screen.
- 10) First Point, Second Point, Third Point & Fourth Point & Flowing Density calibration screen flow has been made as per other MMI devices Screens.
- 11) Fixed SCR 0052795 related to Fault action and Fault level settings.



Emerson Device Revision History Information

(Following NAMUR Recommendation NE53)