



Legal representative entity for the  
European Union:  
Emerson Automation Solutions, Actuation Technologies  
Holland Faszor 6, 8000 Székesfehérvár, Hungary

ROC nr. 11090  
Rev. 3



## EU DECLARATION OF CONFORMITY

Issued in accordance with the  
**EMC Directive 2014/30/EU, Appendix 1**  
**ATEX Directive 2014/34/EU**

We hereby declare, that the products specified below meet the basic health and safety requirements of the above mentioned European Directives.

Product description:	<b>QC54 Foundation Fieldbus Control module</b>
Serial number:	Each Control module has an identifiable serial number
Year of Construction:	Each Control module has an identifiable Year of Construction
Manufacturer:	Emerson Process Management Valve Automation (M) Sdn. Bhd. Lot 13112, Mukim Labu, Kawasan Perindustrian Nilai, 71807 Nilai, Negeri Sembilan Malaysia


### EMC Directive 2014/30/EU

<b>Types:</b>	<b>QC54...</b>
Applicable standards:	IEC61326-1 : 2012      NAMUR Recommendations : NE21: 2015

### ATEX Directive 2014/34/EU

<b>Types:</b>	<b>QC54...P4...</b>
ATEX Certificate No.:	DEKRA 16ATEX0064X
Marking:	Ⓜ II 3 G Ex nA IIC T4 Gc      Ta = -20°C ... +50°C Ⓜ II 2 D Ex tb IIIC T80°C Db
Applicable standards:	EN 60079-0 : 2012 + A11 : 2013    EN 60079-15 : 2010    EN 60079-31 : 2014

<b>Types:</b>	<b>QC54...P1...</b>
ATEX Certificate No.:	DEKRA 16ATEX0064X
Marking:	Ⓜ II 1 G Ex ia IIC T4 Ga Ⓜ II 1 D Ex ia IIIC T80°C Da Ta = -20°C ... +50°C
Applicable standards:	EN 60079-0 : 2012 + A11 : 2013    EN 60079-11 : 2012
Notified body:	DEKRA Certification B.V., Notified body no : 0344 Meander 1051, 6825 MJ Arnhem, The Netherlands

Signed:	
Name:	S. Jones
Position:	Director, Rack and Pinion SBU Emerson Automation Solutions Actuation Technologies

VCCAQ-15300-EN

Date:	2020-03-09
Place:	Houston TX, U.S.A.