

CERTIFICATE OF COMPLIANCE

Certificate Number 20180718-E234790
Report Reference E234790-20120223
Issue Date 2018-JULY-18

Issued to: EGS ELECTRICAL GROUP L L C
9377 W HIGGINS RD
ROSEMONT IL 60018-4973

This is to certify that
representative samples of


COMPONENT - POWER SUPPLIES FOR USE IN ZONE
CLASSIFIED HAZARDOUS LOCATIONS & COMPONENT
- POWER SUPPLIES FOR USE IN HAZARDOUS
LOCATIONS

Please see addendum page

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Please see addendum page
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog
number, model number or other product designation as specified under "Marking" for the particular
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:
, may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180718-E234790
Report Reference E234790-20120223
Issue Date 2018-JULY-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USR - Class I, Zone 2, AEx nA nC IIC Gc Hazardous Locations.

CNR - Class I, Zone 2, Ex nA nC IIC Hazardous Locations.

USR, CNR - Class I, Division 2, Groups A, B, C, and D Hazardous Locations.

Switching Power Supply, Model SDN 10-24-100C, SDN 10-24-100CX, SDN 15-12-100C, SDN 15-12-100CX, SDN 16-12-100C, and SDN 16-12-100CX, may be followed by dash and/or 1-3 alphanumeric characters.

Standard(s) for Safety:

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

CAN/CSA- C22.2 No. 213-17, Nonincendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

