

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification System for Explosive Atmospheres**

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: **IECEx BAS 16.0107X** Page 1 of 4

Certificate history:

Status: Current Issue No: 2

Issue 1 (2018-09-17) Issue 0 (2017-01-17)

2023-11-14 Date of Issue:

Applicant: **Topworx Incorporated**

3300 Fern Valley Road

Kentucky 40213

United States of America

K5L & K7L Switchbox Equipment:

Optional accessory:

Intrinsic Safety & Protection by Enclosure 'tb' Type of Protection:

Ex ia IIC T5/T6 Gb Marking:

Ex tb III C T100°C / T85°C Db ('D' Models only)

Approved for issue on behalf of the IECEx Certification Body:

Position:

Signature: (for printed version)

(for printed version)

R.S. Sinclair

Technical Manager

14/11/2023

This certificate and schedule may only be reproduced in full.
 This certificate is not transferable and remains the property of the issuing body.
 The Status and authenticity of this certificate may be verified by visiting www.iecex.com or use of this QR Code.



Certificate issued by:

SGS UK Limited Rockhead Business Park Staden Lane **Buxton, Derbyshire SK17 9RZ United Kingdom**





IECEx Certificate of Conformity

Certificate No.: **IECEx BAS 16.0107X** Page 2 of 4

Date of issue: 2023-11-14 Issue No: 2

Topworx Incorporated Manufacturer:

3300 Fern Valley Road

Louisville Kentucky 40213

United States of America

Manufacturing locations:

Topworx Incorporated 3300 Fern Valley Road

Louisville

Kentucky 40213

United States of America

Asco Joucomatic Limited Trading as

Asco Numatics 2 Pit Hey Place West Pimbo Skelmersdale

Lancashire WN8 9PG **United Kingdom**

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

STANDARDS:

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

IEC 60079-0:2017 Explosive atmospheres - Part 0: Equipment - General requirements

Edition:7.0

IEC 60079-11:2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

IEC 60079-31:2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

Edition:2

This Certificate does not indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Reports:

GB/BAS/ExTR16.0260/00 GB/SGS/ExTR23.0103/00

Quality Assessment Reports:

GB/SIR/QAR06.0056/11 GB/SIR/QAR07.0025/11



IECEx Certificate of Conformity

Certificate No.: IECEx BAS 16.0107X Page 3 of 4

Date of issue: 2023-11-14 Issue No: 2

EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The K7L Switchbox comprises an aluminium or stainless steel enclosure containing up to two sets of terminals blocks, up to four voltage free switches and up to four certified proximity sensors in any combination and interconnection facilities for remote mounted intrinsically safe equipment connections. The K5L Switchbox is of a similar construction to the K7L but is housed in a low profile enclosure.

Both K5L & K7L versions may include an optional mechanical visual indicator. External electrical connections are made using screw terminals via up to four tapped holes.

Models of the equipment with a 'D' in the model number are gas and dust certified. The installation of the external connections and plugging of the unused entries in these variants must be carried out using appropriately certified IP6X cable glands and blanking plugs.

Models of the equipment marked with a 'G' in the model number are only gas certified. The installation of the external connections and plugging of the unused entries in these variants must be carried out using appropriate cable glands and blanking plugs with a minimum ingress protection of at least IP20. These variants may also be optionally fitted with plug and socket connections fitted to the entries of the enclosure.

See the Certificate Annex for model, electrical and temperature parameters.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1. The cable glands used as entries to the enclosure must be suitably certified cable glands to the requirements of IEC 60079-0, Edition 7, including Annex A, with a minimum IP rating of IP6X in order to comply with the requirements of IEC 60079-31, Edition 2.
- 2. Any unused entries must be fitted with a suitably certified blanking plug certified to the requirements of IEC 60079-0, Edition 7 with a minimum IP rating of IP6X in order to comply with the requirements of IEC 60079-31, Edition 2.



IECEx Certificate of Conformity

Certificate No.: IECEx BAS 16.0107X Page 4 of 4

Date of issue: 2023-11-14 Issue No: 2

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above)

Variation 2.1

Confirm the current equipment design meets the requirements of IEC 60079-0:2017.

Variation 2.2

Introduction of new conditions of use. "X" suffix added to the end of the certificate number.

Variation 2.3

Updated Proximity Sensor information in Annex.

EXTR: GB/SGS/EXTR23.0103/00 File Reference: 21/0357

Annex:

IECEx BAS 16.0107 Annex Iss 0.pdf

Rockhead Business Park Staden lane, Buxton, Derbyshire SK17 9RZ United Kingdom



Date: 2017/01/17

ANNEX to IECEx BAS 16.0107

Issue No. 0

K5L & K7L Switchbox Model Ranges

Dual Gas & Dust Certified 'D' Models

Models of the K5L & K7L Switchbox containing only voltage free (VF) contacts are designated as follows:

Model No. S-M-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20°C ≤Ta ≤+70°C)

Ex tb IIIC T85°C Db (-20°C \leq Ta \leq +70°C)

VF Contact: $U_i = 28V$ $I_i = 120 \text{mA}$ $P_i = 1.3 \text{W}$ $C_i = 0$ $L_i = 0$

Models of the K5L & K7L Switchbox containing only proximity sensors are designated as follows:

Model No. S-F-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20 $^{\circ}$ C \leq Ta \leq +70 $^{\circ}$ C)

Ex tb IIIC T85°C Db (-20°C \leq Ta \leq +70°C)

Each Sensor: $U_i = 15V$ $I_i = 50 \text{mA}$ $P_i = 0.12W$ $C_i = 145 \text{nF}$ $L_i = 340 \mu\text{H}$

Model No. S-P-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (-25° C \leq Ta \leq +57 $^{\circ}$ C)

Ex tb IIIC T100°C Db (-25°C \leq Ta \leq +57°C)

Ex ia IIC T6 Gb (-25° C \leq Ta \leq + 42° C)

Ex tb IIIC T85°C Db (-25°C \leq Ta \leq +42°C)

Each Sensor: $U_i = 16V$ $I_i = 52mA$ $P_i = 0.169W$ $C_i = 100nF$ $L_i = 550\mu H$

Model No. S-PH-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-25°C \leq Ta \leq +70°C)

Ex tb IIIC T85°C Db (-25°C \leq Ta \leq +70°C)

Each Sensor: $U_i = 16V$ $I_i = 25mA$ $P_i = 0.034W$ $C_i = 100nF$ $L_i = 550\mu H$

Model No. S-T-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20° C \leq Ta \leq + 70° C)

Ex tb IIIC T85°C Db (-20°C \leq Ta \leq +70°C)

Each Sensor: $U_i = 20V$ $I_i = 60 \text{mA}$ $P_i = 0.08W$ $C_i = 250 \text{nF}$ $L_i = 350 \mu\text{H}$

Models of the Low Temperature K5L & K7L Switchbox containing only voltage free (VF) contacts are designated as follows:

Model No. S-LM-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-50° C \leq Ta \leq + 70° C)

Ex tb IIIC T85°C Db (-50°C \leq Ta \leq +70°C)

VF Contact: $U_i = 28V$ $I_i = 120 \text{mA}$ $P_i = 1.3W$ $C_i = 0$ $L_i = 0$

Rockhead Business Park Staden Iane, Buxton, Derbyshire SK17 9RZ United Kingdom



Date: 2017/01/17

ANNEX to IECEx BAS 16.0107

Issue No. 0

Models of the Low Temperature K5L & K7L Switchbox containing only proximity sensors are designated as follows:

Model No. S-LF-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (- 40° C \leq Ta \leq + 60° C) Ex tb IIIC T85°C Db (- 40° C \leq Ta \leq + 60° C)

Each Sensor: $U_i = 15V$ $I_i = 50 \text{mA}$ $P_i = 0.12 \text{W}$ $C_i = 150 \text{nF}$ $L_i = 150 \text{\mu}\text{H}$

Model No. S-LP-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (- 40° C \leq Ta \leq + 60° C) Ex tb IIIC T100°C Db (- 40° C \leq Ta \leq + 60° C) Ex ia IIC T6 Gb (- 40° C \leq Ta \leq + 45° C) Ex tb IIIC T85°C Db (- 40° C \leq Ta \leq + 45° C)

Each Sensor: $U_i = 16V$ $I_i = 52mA$ $P_i = 0.169W$ $C_i = 120nF$ $L_i = 200\mu H$

Model No. S-LPH-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-40° C \leq Ta \leq + 70° C) Ex tb IIIC T85°C Db (-40° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 16V$ $I_i = 25\text{mA}$ $P_i = 0.034W$ $C_i = 120\text{nF}$ $L_i = 200\mu\text{H}$

Model No. S-LP-D-50-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (-50°C \leq Ta \leq +60°C) Ex tb IIIC T100°C Db (-50°C \leq Ta \leq +60°C) Ex ia IIC T6 Gb (-50°C \leq Ta \leq +45°C) Ex tb IIIC T85°C Db (-50°C \leq Ta \leq +45°C)

Each Sensor: $U_i = 16V$ $I_i = 52mA$ $P_i = 0.169W$ $C_i = 70nF$ $L_i = 150\mu H$

Model No. S-LPH-D-50-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-50° C \leq Ta \leq + 70° C) Ex tb IIIC T85 $^{\circ}$ C Db (-50° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 16V$ $I_i = 25\text{mA}$ $P_i = 0.034W$ $C_i = 70\text{nF}$ $L_i = 150\mu\text{H}$

Model No. S-LT-D-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (- 40° C \leq Ta \leq + 70° C) Ex tb IIIC T85 $^{\circ}$ C Db (- 40° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 20V$ $I_i = 20\text{mA}$ $P_i = 0.20W$ $C_i = 150\text{nF}$ $L_i = 150\mu\text{H}$

Rockhead Business Park Staden lane, Buxton, Derbyshire SK17 9RZ United Kingdom



Date: 2017/01/17

ANNEX to IECEx BAS 16.0107

Issue No. 0

Gas only Certified 'G' Models

Models of the K5L & K7L Switchbox containing only voltage free (VF) contacts are designated as follows:

Model No. S-M-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20° C \leq Ta \leq + 70° C)

VF Contact: $U_i = 28V$ $I_i = 120 \text{mA}$ $P_i = 1.3W$ $C_i = 0$ $L_i = 0$

Models of the K5L & K7L Switchbox containing only proximity sensors are designated as follows:

Model No. S-F-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 15V$ $I_i = 50 \text{mA}$ $P_i = 0.12W$ $C_i = 145 \text{nF}$ $L_i = 340 \mu\text{H}$

Model No. S-P-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (-25° C \leq Ta \leq +57 $^{\circ}$ C)

Ex ia IIC T6 Gb (-25° C \leq Ta \leq + 42° C)

Each Sensor: $U_i = 16V$ $I_i = 52\text{mA}$ $P_i = 0.169W$ $C_i = 100\text{nF}$ $L_i = 550\mu\text{H}$

Model No. S-PH-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-25°C \leq Ta \leq +70°C)

Each Sensor: $U_i = 16V$ $I_i = 25mA$ $P_i = 0.034W$ $C_i = 100nF$ $L_i = 550\mu H$

Model No. S-T-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-20° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 20V$ $I_i = 60 \text{mA}$ $P_i = 0.08W$ $C_i = 250 \text{nF}$ $L_i = 350 \mu \text{H}$

Models of the Low Temperature K5L & K7L Switchbox containing only voltage free (VF) contacts are designated as follows:

Model No. S-LM-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-50°C \leq Ta \leq +70°C)

VF Contact: $U_i = 28V$ $I_i = 120 \text{mA}$ $P_i = 1.3 \text{W}$ $C_i = 0$ $L_i = 0$

Models of the Low Temperature K5L & K7L Switchbox containing only proximity sensors are designated as follows:

Model No. S-LF-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-40° C \leq Ta \leq + 60° C)

Each Sensor: $U_i = 15V$ $I_i = 50 \text{mA}$ $P_i = 0.12 \text{W}$ $C_i = 150 \text{nF}$ $L_i = 150 \text{\mu}$ H

Rockhead Business Park Staden lane, Buxton, Derbyshire SK17 9RZ United Kingdom



Date: 2017/01/17

ANNEX to IECEx BAS 16.0107

Issue No. 0

Model No. S-LP-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (- 40° C \leq Ta \leq + 60° C) Ex ia IIC T6 Gb (- 40° C \leq Ta \leq + 45° C)

Each Sensor: $U_i = 16V$ $I_i = 52\text{mA}$ $P_i = 0.169W$ $C_i = 120\text{nF}$ $L_i = 200\mu\text{H}$

Model No. S-LPH-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-40° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 16V$ $I_i = 25\text{mA}$ $P_i = 0.034W$ $C_i = 120\text{nF}$ $L_i = 200\mu\text{H}$

Model No. S-LP-G-50-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T5 Gb (-50°C \leq Ta \leq +60°C)

Ex ia IIC T6 Gb (-50° C \leq Ta \leq + 45° C)

Each Sensor: $U_i = 16V$ $I_i = 52\text{mA}$ $P_i = 0.169W$ $C_i = 70\text{nF}$ $L_i = 150\mu\text{H}$

Model No. S-LPH-G-50-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-50° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 16V$ $I_i = 25\text{mA}$ $P_i = 0.034W$ $C_i = 70\text{nF}$ $L_i = 150\mu\text{H}$

Model No. S-LT-G-IEC

No indicator or indicator ≤20cm² surface area

Ex ia IIC T6 Gb (-40° C \leq Ta \leq + 70° C)

Each Sensor: $U_i = 20V$ $I_i = 20mA$ $P_i = 0.20W$ $C_i = 150nF$ $L_i = 150\mu H$

Where interconnection facilities for remote mounted intrinsically safe equipment connections are fitted, the input parameters for these terminals for all models are as follows: -

 $U_i = 30V$

Details of these terminal arrangements including interconnections are detailed on an internal label within the equipment.

Rockhead Business Park Staden lane, Buxton, Derbyshire SK17 9RZ United Kingdom



ANNEX to IECEx BAS 16.0107

Issue No. 0

Date: 2017/01/17

Proximity Sensor Information

The following certified Proximity Sensors are fitted in the various models of the equipment:

Sensor	IECEx Certificate No.	Standards
K5L & K7L Switchbox Model No.'s S-P-*-IEC & S-PH-*-IEC		
Pepperl + Fuchs - Slot-type Proximity Sensors	IECEx PTB 11.0091X	IEC 60079-0: 2011 Ed. 6 IEC 60079-11: 2006 Ed. 5
		IEC 60079-11. 2006 Ed. 3
Pepperl + Fuchs - Cuboidal Inductive Proximity	IECEx PTB 11.0021X	IEC 60079-0: 2004 Ed. 4
Sensors		IEC 60079-11: 2006 Ed. 5
		IEC 60079-26: 2006 Ed. 2
Pepperl + Fuchs - Cylindrical Inductive Proximity	IECEx PTB 11.0037X	IEC 60079-0: 2004 Ed. 4
Sensors		IEC 60079-11: 2006 Ed. 5
		IEC 60079-26: 2006 Ed. 2
Pepperl + Fuchs - SN-Type Proximity Sensors	IECEx PTB 11.0092X	IEC 60079-0: 2011 Ed. 6
		IEC 60079-11: 2006 Ed. 5
		IEC 60079-26: 2006 Ed. 2
K5L & K7L Switchbox Model No.'s S-LP-*-IEC & S-LPH-*-IEC		
Pepperl + Fuchs - SN-Type Proximity Sensors	IECEx PTB 11.0092X	IEC 60079-0: 2011 Ed. 6
		IEC 60079-11: 2006 Ed. 5
		IEC 60079-26: 2006 Ed. 2
K5L & K7L Switchbox Model No.'s S-LP-*-50-IEC & S-LPH-*-50-IEC		
Pepperl + Fuchs - SN-Type Proximity Sensors	IECEx PTB 11.0092X	IEC 60079-0: 2011 Ed. 6
		IEC 60079-11: 2006 Ed. 5
VEL 9 V7L Switchbox Model No. S. E.* IEC		IEC 60079-26: 2006 Ed. 2
K5L & K7L Switchbox Model No. S-F-*-IEC IFM Electronic GmbH - Inductive Proximity Switch IECEx BVS 06.0003 IEC 60079-0: 2011 Ed. 6		
IFM Electronic GmbH - Inductive Proximity Switch	IECEX BVS 06.0003	IEC 60079-0: 2011 Ed. 6 IEC 60079-11: 2011 Ed. 6
Types N*50*A, NN5013, NN5017, NN5018,		
N95001, N*500*, KI5030 K5L & K7L Switchbox Model No. S-LF-*-IEC		IEC 60079-26: 2006 Ed. 2
IFM Electronic GmbH – Inductive Proximity	IECEx BVS 09.0016	IEC 60079-0: 2011 Ed. 6
Sensors	IECEX BVS 09.0016	IEC 60079-0. 2011 Ed. 6
Selisors		IEC 60079-11. 2011 Ed. 0
K5L & K7L Switchbox Model No. S-T-*-IEC		1LO 00013-20. 2000 Eu. 2
Hans Turck GmbH & Co. KG – Two Wire	IECEx KEM 06.0036X	IEC 60079-0: 2011 Ed. 6
Proximity Sensors TypesY1/	ILOLX KEW 00.0030X	IEC 60079-0. 2011 Ed. 6
Froximity Sensors Types11/		IEC 60079-11: 2011 Ed. 0
K5L & K7L Switchbox Model No. S-LT-*-IEC		
Hans Turck GmbH & Co. KG - Two Wire	IECEx KEM 06.0036X	IEC 60079-0: 2011 Ed. 6
Proximity Sensors TypesY1/		IEC 60079-11: 2011 Ed. 6
		IEC 60079-26: 2006 Ed. 2

Where the above sensors are certified to older editions of the standards than those listed for the K5L & K7L Switchbox, the differences between the editions of the standards listed have been reviewed and determined to have no technical differences affecting the sensors.