
Sentronic^D Digital Electronic Pressure Regulator

Installation Manual





Sentronic^D

1	Description	3
1.1	How To Order	3
1.2	Operating Elements	
1.3	Manual Pressure Regulation	
1.4	Operating Modes	
2	Electrical Connection	5
3	Analog Setpoint - Outlet Pressure	6
4	Pneumatic Connection	7
5	Factory Settings for a Standard Valve	7
6	Field-programmable settings	8
7	Technical characteristics	
7.1	Fluid characteristics	8
7.2	Specifications	8
8	Accessories	Q
9	Maintenance and care	Q
10	Dimensions and weights	10



CAUTION OBSERVE PRECAUTIONS FOR HANDLING ELECTROSTATIC SENSITIVE DEVICES

This product contains electronic components sensitive to electrostatic discharge. An electrostatic discharge generated by a person or object coming in contact with the electrical components can damage or destroy the product.

To avoid the risk of electrostatic discharge, please observe the handling precautions and recommendations contained in standard EN 100015-1. Do not connect or disconnect the device while it is energised.



CAUTION! Dangerous operating conditions may occur when using the programming interface on the valve as the valve may possibly not react to the analog setpoint any more.

Provide for protection against uncontrolled movement of equipment when putting the valve into operation and before making any modifications to the valve settings.

DECLARATION OF INCORPORATION

according to Machinery Directive 89/392/EEC, Annex II B

We herewith declare that the version of the product described in this installation manual is intended to be incorporated into or assembled with other machinery and that it must not be put into service until the machinery into which it is to be incorporated has been declared in conformity with the provisions of Council Directive 89/392/EEC, Annex IIB.

Handling, assembly and putting into service and all settings and adjustments must be done by qualified, authorised personnel only.



This product complies with the essential requirements of the EMC Directive 89/336/EEC and its amendments. It is **CE**-approved. A separate Declaration of Conformity is available on request.

A separate Declaration of Incorporation relating to the EU Directive 89/392/EEC Annex II B is available on request. Please provide ordering code and serial numbers of products concerned.

NOTICE

The information in this manual is subject to change without notice.

In no event shall Emerson be liable for technical or editorial errors or omissions. Neither is any liability assumed for accidental or consequential damages arising out of or in connection with the supply or use of the information contained herein.

THIS MANUAL CONTAINS INFORMATION PROTECTED BY COPYRIGHT. NO PART OF THIS DOCUMENT MAY BE PHOTOCOPIED OR REPRODUCED IN ANY FORM OR MANNER WHATSOEVER WITHOUT PRIOR WRITTEN PERMISSION FROM EMERSON.



1. Description

SENTRONIC^D is a new generation of electronic pressure regulators designed on the basis of an enhanced digital control. **S**ENTRONIC^D stands for:

Digital communication and control

Display (incorporated)

Direct operated valve

Dynamic behaviour (high speed)

Digital control offers many advantages during installation and start-up of the **Sentronic**^D valve and extended possibilities to adapt it to various applications.

The four following standard versions are available:

With display and pushbuttons:
 Pressure display, manual pressure setting and diagnostic LEDs.


• Without display and pushbuttons: The economic solution.

Nominal diameter DN 4mm: with a flow rate of 470 l/min (SRA).
 Nominal diameter DN 8mm: with a flow rate of 1300 l/min (SRA).

Various pneumatic connections: integral connections, back panel connection and subbase mount.

- All pressure and exhaust ports are the same size, which allows for short response times when the pressure is increased or decreased.
- Digital pressure control in a closed loop: An internal pressure sensor compares the setpoint at the inlet to the outlet pressure. The outlet pressure is adjusted in real time.
- The control parameters can be changed with the additional software called *DaS*. The *DaS* program (Data Acquisition Software) ensures that all parameters used by the valve can be changed. This flexibility allows the valve to be adapted to the application and enables the optimization of its response time, overshoot and precision.
- After having set the optimum parameters you can save them in a project file for your personal use or send them to our Product Support for future production.

1.1 How to Order





1.2 Operating Elements



- Proportional solenoid coil 1
- 2.1 Pressure supply
- 2.2 Pressure outlet
- 2.3 **Exhaust**
- 3 Power supply, M12 connector
- 4 Operator buttons
- 5 3-digit display of outlet pressure
- 6 Ground connection, M4
- 7 Threaded mounting holes M4/6 mm
- 8 Mounting holes for M4 screws
- 9.1 Green LED

OFF: Setpoint ≠ feedback ON: Setpoint = feedback

Flashing:Overtemperature

9.2 Yellow LED

> OFF: Normal

ON: Manual operation

Flashing: AUTOSAFE enabled

9.3 **Red LED**

> OFF: Normal

ON: Low voltage

Flashing: Overvoltage

10 Serial communication (PC connection)

1.3 Manual Pressure Regulation (Hand)

After an interruption in the power supply, press both arrow buttons located beneath the display during power up to switch to the manual mode. The operating mode is indicated by the letters "H n d" in the display.

The "H n d" display disappears when the arrow buttons are released.

Press the left arrow button or DOWN arrow to reduce the outlet pressure, press the right arrow button or UP arrow to increase the outlet pressure. The yellow LED is on permanently during manual mode.

Exit this operating mode by pressing both arrow buttons simultaneously or by turning off the power supply for a short time.

1.4 Operating Modes

Shut-off:

If the command signal falls below 0.5 %, the coil current is switched off and the valve is fully exhausted.

Overtemperature:

If the temperature of the internal control electronics exceeds 100°C, the operating mode is switched to AUTOSAFE and the green LED starts to flash.


Undervoltage / overvoltage:

If the supply voltage is less than 20 V or more than 30 V, the coil current is switched off and the valve is fully exhausted. The red LED lights up constantly to indicate undervoltage or flashes to indicate overvoltage.

Autosafe:

If the coil current exceeds 1000 mA (DN8) or 560 mA (DN4) for more than 20 seconds, the output current is limited to max. 70% every 4 seconds to prevent the valve from overheating. The yellow LED flashes.






- 1) The valve must only be supplied with 24V DC at a tolerance of +15%/-10% and a max. ripple of 10% (no supply via diode bridge). Overvoltage or a ripple rate exceeding these tolerances can damage the electronics.
- 2) The max. current at the digital output is 200 mA/4.8W (PNP output). The output is protected against short circuit and overload.
- 3) If a relay (inductive load) is connected to the digital output, a freewheel diode or a varistor must be used.
- 4) A shielded cable must be used for protection against interference and EMC.
- 5) The valve body must be grounded with the earthing terminal PE (dia. M4)

Connector Pin Out

Command signal: View on soldered side of female connector




PIN	Description			
1	+24 VDC Supply			
2	Command Signal			
3	+0 VDC Common (Supply)			
	+0 VDC Common (Command Signal)*			
4	Analog output (feedback)			
5	Digital output (pressure switch)			
Body	EMC shield			

^{*}A 6-wire cable with separate common for the command signal is used for cable lengths over 2 m to minimize the voltage drop for the command signal.

3. Analog Setpoint - Outlet Pressure

Setpoint offset

The pressure setpoint zero can be changed via the DaS program. Switch to "Custom" in the "Setpoint setting" section. The zero range is max. ±50 %.




Max. Outlet Pressure PMR	Max. Inlet Pressure
50 psi	90 psi
100 psi	140 psi
150 psi	190 psi
1 bar	4 bar
3 bar	6 bar
6 bar	9 bar
10 bar	13 bar
12 bar	15 bar
15 bar	18 bar

CAUTION: Outlet pressures above the maximum outlet pressure (PMR) are not controlled by the valve, i.e. the max. outlet pressure is limited to the PMR.

In order to avoid damaging the sensor, the supply pressure must always be less than the maximum inlet pressure defined above (see table).

Setpoint span

The span of the output pressure can be changed via the DaS program. Switch to "Custom" in the "Setpoint setting" section. The span is between 10 and 100%.



The span can be set to max. 100% of the maximum outlet pressure (PMR). It can only be decreased.

4. Pneumatic Connection

The air flow is from port 1 to port 2.



Inch screw connections (pipe threads) must be used.

Each screw connections must be lined with a fitting synthetic sealing disc.

Do not use Teflon sealing tape or hemp as they may get inside the valve and damage it.

Use an appropriate silencer at port (3). The exhaust time may vary depending on the type of silencer used.

The diameter of the pneumatic lines must be adjusted to the nominal diameter of the valve. The diameter of outlet line (2) must be larger or equal to that of inlet line (1).

The supply pressure must always be less than the value given in the table in section 3 and must always be above the desired outlet pressure.

5. Factory Settings for a Standard Valve

- 0 psi outlet pressure at a setpoint of 0 V / 0 mA / 4 mA.
- Span: 50 psi device: = 50 psi at 10 V / 20 mA

100 psi device: = 100 psi at 10 V / 20 mA 150 psi device: = 150 psi at 10 V / 20 mA • Minimum hysteresis. 3 bar device: = 3 bar at 10 V / 20 mA • bar device: = 6 bar at 10 V / 20 mA 10 bar device: = 10 bar at 10 V / 20 mA

• The control parameters, setpoint offset, setpoint span and window size of the digital output (pressure switch) are factory-programmed.

Parameter set: factory settings

Offset: 0 % Span: 100 % Ramp: no ramp

Shut-off: ON; the valve is exhausted at a command signal below 0.5%

Controller structure: PID Proportional gain: 4.0 Integration time: 0.1 sec Derivation time: 8 msec



6. Field-Programmable Settings

Display/Pressure Readings

The actual outlet pressure is displayed during normal operation. See "Parameters/Display" section. Other displays:

Hnd indicates that the Manual mode has been selected.

SOF Internal error of pressure control. Replace valve or contact our Product Support.

Err Internal overflow.

AEr Autozero overflow. Contact our Product Support.

Push Buttons

To enter the Manual mode, press and hold both pushbuttons simultaneously during power up. "Hnd" appears in the display. Use the UP button to increase the outlet pressure and the DOWN button to decrease it. The actual outlet pressure is displayed.

Quick presses on the buttons allow you to make slight changes in the pressure rating.

Longer presses allow you to make quick pressure changes.

Press both pushbuttons simultaneously to exit the manual mode.

7. Technical Characteristics

Construction Installation

Directly operated valve Assembly position: any; for optimum performance vertically

with solenoid at the top. Body: Aluminium with solenoid at the top. Air: filtered at 50 μ m, free of condensate

Internal parts: POM Connections: Hemp or Teflon tape must not be used.

Seals: NBR (nitrile), FPM (fluoroelastomer)

Electrical connection: Select a wire section that will give a

voltage drop of less than 2 volts at 2A.

7.1 Fluid Characteristics

Fluids: Air or neutral gas, filtered at 50 μm, free of condensate, lubricated or not

Ports: 1/8-1/4-3/8 NPT or GTap, see section 3

Max. Inlet Pressure: see section 3

 Temperature / Fluid:
 32°F - 140°F (0°C - 60°C)

 Temperature / Ambient:
 32°F - 122°F (0°C - 50°C)

 Temperature / Ambient:
 32°F - 122°F (0°C - 50°C)

Hystersis: <1% of span
Linearity: <0.5% of span
Repeatability: <0.5% of span

Minimum Setpoint: 100mV (0.2 mA/4.2mA) with shut-off function

Minimum Outlet Pressure: <1% of span

7.2 Specifications

Nominal diam-	Supply voltage (stabilised)* (W)	May Current	Insulation	Degree of	Flow		Electrical	
eter dn (mm)			(mA)	Class	Protection	Kv Nm³/h	l/min (SRA)	Connection
4	24 V = +15%/-10%	21	850	Н	IP 65	0.25	470	5-pin female M12 connector
8	24 V = +15%/-10%	40	1650	Н	IP 65	0.7	1300	5-pin female M12 connector

^{*} Residual ripple: 10 %

Test conditions according to ISO 8778: temperature: 20 °C, relative inlet pressure: 6 bar, relative outlet pressure: 5 bar

Command signal: 0 ... 10 V (100 kOhm input resistance)

Feedback output: 0 ... 20 mA / 4 ... 20 mA (250 Ohm input resistance) 0 ... 10 V (max. 10 mA), short-circuit protected 0 ... 20 mA / 4 ... 20 mA (max. 24 VDC)

Digital output: pnp; open collector; max. 200 mA/4.8W, short-circuit protected

HIGH (24 VDC) if feedback=setpoint LOW (open) if feedback≠setpoint

Overvoltage: Shut-off at a voltage level higher than 30 volts (+10%). Low voltage: Shut-off at a voltage level lower than 19.5 volts (-10 %).



8. Accessories

5 Pin 12mm FEMALE Straight Field Att	Model Number					
PG 9 Cable Gland	TC05F20000000000					
5 Pin 12mm FEMALE 90 DEGREE Field	Attachable Connectors					
PG 9 Cable Gland	TD05F20000000000					
Micro Female 5 Pole Straight 6 Wire 2	2 AWG, Shielded					
3 Meter	TC0503MMS000671Y					
5 Meter	TC0505MMS000671Y					
Micro Female 5 Pole 90 Degree 6 Wire 22 AWG Euro Color Code, Shielded						
3 Meter	TD0503MMS000671Y					
5 Meter	TD0505MMS000671Y					
— Micro F/M 4 Pole Straight 22 AWG Euro Color Code						
Unshielded	elded					
2 Meter - TC0403MIETA04000	03MMETA04000					
5 Meter - TC0405MIETA04000	5 Meter - TC04	05MMETA04000				
— Micro F 90°/M Straight 22 AWG Euro Color Code						
Unshielded	elded					
2 Meter - TD0403MIETA04000		03MMETA04000				
5 Meter - TD0405MIETA04000	rer - TD0405MIETA04000 5 Meter - TD04					
Manifold		Model Number				
Manifold for 608 (DN 4mm) with G3/8;	35500558					
Manifold for 609 (DN 8mm) with G1/2;	35500559					
PC Software & Cable Connectors	Model Number					
DaS Light: Data Acquisition Software for free download at Emerson.com	99100110					

DaS Expert: Data Acquisition Software for Sentronic^D - full parameters - CD-ROM

RS 232 cable converter; 2m cable with 9-pin Sub-D (plug connector)

RS 232 cable converter; 2m cable with 9-pin Sub-D (screw connector)

9. Maintenance and Care

No special maintenance or care required.



99100111

88100732

833-993708

¹⁾ Manifold ships with required hardware and gaskets for connecting manifolds together.

10. Dimensions in inches (mm), Weight in lbs (kg)


Dimensions: Inches (mm), Weight in lbs (kg)


Inline version: DN 4 Weight: 1.23 (0.56) M4 hole for earth screw G1/8", G1/4" M12x1 -G1/8", G1/4" 111,5 Hole for M4 screw (*) 65 54 43,55 29,5 20 Hole for Programming 21,5 M4 screw (*) Interface 56,3 43 67,8 52 Connector Fixing holes: M4 thread Inline version: DN 8 Weight: 2.49 (1.13) M4 für Befestigung 24 20 40 66 Ø 45 M4 für Erdungsschraube Befestigung mit M4 Schrauben G3/8" 137,5 Anschluss-Stecker 72,5 67,63,55 42,3 9 G3/8" 16,3 25 Programmier-Stecker 28 48,5 57,15


Dimensions: Inches (mm), Weight in lbs (kg)


Manifold version: DN 4

Weight: 1.23 (0.56)











56,3



Manifold: DN 4



1.61 (41)

Dimensions: Inches (mm), Weight in lbs (kg)

Manifold version: DN 8 Weight: 2.49 (1.13) 77,8 66 M4 für Erdungsschraube Befestigung mit M4 Schrauben 9 137,48 ėėė ė G1/4" M12 x1 72,5 63,55 48,5 66,3 Programmier-Schnittstelle 57,15 28 56 2.01 (51) Manifold: DN 8 **∭♦** 3/8 GTap 1.81 (46) Hole for 2.68 (68) 0.31 (8) 1.02 (26) M4 screw 2.01 (51) 2.17 (55) 0.83 (21) \mathbb{H} 2.68 (68) 1/2 GTap 1/2 GTap 4.53 (115) 4.72 (120) 1/2 GTap 1/2 GTap \mathbb{H} \oplus 2.40 (61) Hole for M4 screw

12