



Certificate no. TAI-FS-C-23-0018

WE HEREBY CERTIFY THAT

Product description HYDRAULIC SCOTCH-YOKE SPRING RETURN AND
DOUBLE ACTING ACTUATOR

Models BETTIS™ SERIES G

Manufacturer EMERSON AUTOMATION SOLUTIONS
Valve Automation, Inc.
19200 Northwest Freeway
Houston, Texas 77065
USA

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION
SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-23-0038

Expiry date 16.04.2026

Issue date 17.04.2023

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
17.04.2023, Monte Roberto (AN)

Page 1 of 2

Ing. Crescenzo Di Fratta

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
Sede operativa: Via dell'Industria, 14 – 25030 Erbusco - Brescia, Italy
Phone +39 030 9821049 Fax +39 030 9822253 info.bs@tuvaustraliaitalia.com
Sede legale: Via del Commercio, 6/A - 60030 Monte Roberto - Ancona, Italy
Cap. Soc. i.v. EUR 10.000,00; R.I. Ancona – C.F. – P. IVA 02217380423
Cod. Id. CEE IT02217380423 REA AN n. 170070
A socio unico, soggetta a controllo e coordinamento di:
TÜV AUSTRIA HOLDING AG, Deutschstrasse 10, 1230, Vienna, Austria
www.tuvaustriaitalia.com www.tuv.at

Annex to certificate no. TAI-FS-C-23-0018

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_s [1/h]
Bettis™ series G spring return - No PST	1	3,56E-08	0,00E+00	0,00E+00
Bettis™ series G spring return - With PST	1	3,20E-09	3,24E-08	0,00E+00
Bettis™ series G double acting - No PST	1	3,90E-08	0,00E+00	0,00E+00
Bettis™ series G double acting - With PST	1	3,51E-09	3,55E-08	0,00E+00

Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

- Remarks:**
- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manuals ES 47_G

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
17.04.2023, Monte Roberto (AN)



Ing. Crescenzo Di Fratta