



Certificate no. TAI-FS-C-22-0005 Rev. 01

WE HEREBY CERTIFY THAT

Product description PNEUMATIC RACK AND PINION SPRING RETURN AND DOUBLE ACTING ACTUATOR

Models BETTIS™ SERIES RPE (up to and including size 0600)

Manufacturer EMERSON AUTOMATION SOLUTIONS
Valve Automation, Inc.
19200 Northwest Freeway
Houston, Texas 77065
USA

IS IN COMPLIANCE WITH THE REQUIREMENTS OF THE STANDARDS

IEC 61508 Parts 1–7:2010

AS RESULT OF THE ASSESSMENT ACCORDING TO THE PROVISION SET OUT IN THE ABOVE-MENTIONED STANDARDS

Summary Report no. TAI-FS-R-22-0010 Rev. 01

Expiry date 24.02.2025

Issue date 03.05.2023

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
03.05.2023, Monte Roberto (AN)

Ing. Crescenzo Di Fratta

Page 1 of 2

Annex to certificate no. TAI-FS-C-22-0005 Rev. 01

Type	A
HFT	0
Safety functions	<u>Spring return actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the spring, with power fluid exhausted from the cylinder through the control system <u>Double acting actuators:</u> 1. Delivery of a full stroke ($90^\circ \pm$ tolerance) driven by the piston of cylinder, powered by the specified medium working pressure
Mode of operation	Low Demand Mode

Random failure rates				
Configuration	Safety function	λ_{DU} [1/h]	λ_{DD} [1/h]	λ_S [1/h]
Bettis™ series RPE spring return - No PST	1	1,50E-08	0,00E+00	0,00E+00
Bettis™ series RPE spring return - With PST	1	1,35E-09	1,37E-08	0,00E+00
Bettis™ series RPE double acting - No PST	1	1,77E-08	0,00E+00	0,00E+00
Bettis™ series RPE double acting - With PST	1	1,59E-09	1,61E-08	0,00E+00


Systematic capability	3 (Route 1s applied)			
Architectural constraints	Route 1_H:	Applied	Route 2_H:	Applied
	The product can be used in: <ul style="list-style-type: none"> • single channel configuration: <ul style="list-style-type: none"> ○ up to SIL 2 without external diagnostic tests ○ up to SIL 3 considering external diagnostic tests • double channel configuration: up to SIL 3 			

Remarks:

- For further details, including environmental conditions, limitations of use, lifetime, failure rates traceability, mean repair times, common cause factors and systematic capability constraints, make reference to Safety Manual DOC.SILM.BE.EN.

END OF CERTIFICATE

TÜV AUSTRIA ITALIA - Blu Solutions s.r.l.
03.05.2023, Monte Roberto (AN)



Ing. Crescenzo Di Fratta